

99006055005005, 99006055005005

Construction and operation of a plant requiring monitoring in accordance with the Ordinance on Industrial Safety and Health Authorization of filling stations

Heruntergeladen am 29.06.2025

<https://fimportal.de/xzufi-services/407093877/L100008>

Modul	Sachverhalt
Leistungsschlüssel	99006055005005, 99006055005005
Leistungsbezeichnung I	Construction and operation of a plant requiring monitoring in accordance with the Ordinance on Industrial Safety and Health Authorization of filling stations
Leistungsbezeichnung II	
Typisierung	2 - Bundesauftragsverwaltung: Regelung
Quellredaktion	Sachsen-Anhalt
Freigabestatus Katalog	unbestimmter Freigabestatus
Freigabestatus Bibliothek	fachlich freigegeben (silber)
Begriffe im Kontext	

Modul	Sachverhalt
Leistungstyp	Leistungsobjekt mit Verrichtung
Leistungsgruppierung	Arbeitsschutz (006)
Verrichtungskennung	Erlaubnis (005)
SDG-Informationsbereich	Gesundheits- und Sicherheitsvorschriften im Zusammenhang mit verschiedenen Arten von Tätigkeiten, einschließlich der Risikovermeidung, Information und Ausbildung
Lagen Portalverbund	
Einheitlicher Ansprechpartner	Nein
Fachlich freigegeben am	11.01.2023
Fachlich freigegeben durch	Ministry of Labour, Social Affairs, Transformation and Digitalization Rhineland-Palatinate (MASTD)
Handlungsgrundlage	https://www.gesetze-im-internet.de/betrsv_2015/_18.html https://www.gesetze-im-internet.de/betrsv_2015/_18.html
Teaser	If you wish to set up, operate or make certain changes to a filling station, you must apply for a permit from the competent authority.
Volltext	<p>Filling stations are fixed installations or installations permanently used at the same location with a handling capacity of more than 1000 liters per hour. Filling stations are used to fill transport containers with flammable liquids. This is a facility that requires monitoring.</p> <p>You require a permit from the competent authority if you:</p> <ul style="list-style-type: none"> • wish to set up and operate a filling station • wish to make changes to the design or mode of operation that affect the safety of the system. <p>Permission may be granted subject to the following restrictions:</p>

Modul

Sachverhalt

- limited,
- limited in time,
- subject to conditions or
- with conditions.

If the installation requiring a permit is part of an installation requiring a permit, no separate permit will be issued. The authorization includes the permit.

Erforderliche Unterlagen

Informal application with the following details:

- Surname, first name, company name
- Address of the applicant
- Contact information (e-mail, telephone, fax)
- Type of permit Construction and operation
Modification and operation or Partial permit
- Specification of the operating site

Documents required to assess the installation:

- Subject of the application
 - Description of the installation
 - Description of the system technology and interaction with other systems
 - Piping and instrument flow diagram (P&I flow diagram)
 - Safety data sheets
 - Description of operation
 - General plan
 - Site plan
 - Floor plan/technical plan
 - Ex zone plan
 - Explosion protection concept
 - Information on fire protection
 - Description of the liquid-tight area
 - Calculation of production costs
 - Other systems
 - Test report from an approved inspection body (ZÜS)
- The test report must confirm that the system can be operated safely if the specified measures are complied with.

Voraussetzungen

- The facility for which you are applying for a permit must be a facility requiring a permit.

Modul

Sachverhalt

- You must construct and operate filling stations in accordance with the state of the art.
- Your documentation must be complete, plausible and meaningful.
- The test report from the approved inspection body (ZÜS) must confirm that the system applied for can be operated safely if the measures specified in the documents, including the tests, are complied with.

Kosten

Verfahrensablauf

- Submit the application for approval of the system requiring monitoring with the required documents including the test report from the approved monitoring body (ZÜS) to the responsible authority.
- If a permit is required in accordance with the Federal Immission Control Act, you will receive the application documents back, as a permit in accordance with the Industrial Safety Ordinance will then also be checked as part of the necessary permit in accordance with the Federal Immission Control Act.
- The competent authority will make its decision after examination and inform you.

Bearbeitungsdauer

0 - 3 Monat(e)
 The processing period applies from receipt of the complete application documents. An extension of the processing period is possible in justified cases.

Frist

The permit expires if: • you have not commenced construction of the installation within two years of the permit being issued, • you have interrupted the construction of the installation for two years or longer or • you have not operated the installation for a period of three years. You can apply to the licensing authority for an extension of the deadlines for important reasons.

weiterführende Informationen

Hinweise

Rechtsbehelf

Kurztext

- Construction and operation of an installation

Modul
Sachverhalt

requiring monitoring in accordance with the Ordinance on Industrial Safety and Health Authorization of filling stations

- A filling station is a fixed installation or an installation permanently used at the same location with a handling capacity of more than 1000 liters per hour
- They are "systems requiring monitoring" that must be assembled, installed and operated in accordance with the state of the art.
- Anyone wishing to set up, operate or make changes to the design and mode of operation of such a filling station requires a permit.
- The permit can: granted subject to conditions, limited, limited in time and be subject to conditions.
- Application: informally in writing or electronically
- An application for a partial permit is possible
- Required documents, including Subject of the application Description of the installation Description of the system technology and interaction with other systems Piping and instrument flow diagram (P&I flow diagram) Test report from an approved inspection body (ZÜS)
- Responsible: Occupational health and safety authority or trade supervisory authority

Ansprechpunkt
Zuständige Stelle
Formulare

Forms available: No

Written form required: Yes

Informal application possible: Yes

Personal appearance necessary: No

Online services available: No

Ursprungsportal

Construction and operation of a plant requiring monitoring in accordance with the Ordinance on Industrial Safety and Health Authorization of filling stations, Errichtung und Betrieb einer überwachungsbedürftigen Anlage nach Betriebssicherheitsverordnung Erlaubnis von Füllstellen